



Certificate / Certificat Zertifikat / 合格証

AEA 1902082 C005

exida hereby confirms that the:

Triple Eccentric Butterfly Valve Aira Euro Automation Pvt Ltd Ahmedabad - India

The manufacturer
may use the mark:



Has been assessed per the relevant requirements of:

IEC 61508 : 2010 Parts 1-7

and meets requirements providing a level of integrity to:

Systematic Capability: SC 3 (SIL 3 Capable)

Random Capability: Type A, Route 2_H Device

**PFH/PFD_{AVG} and Architecture Constraints
must be verified for each application**

Revision 1.0 February 26, 2021

Surveillance Audit Due
March 01, 2024

Safety Function:

The Butterfly Valve will move to the designed safe position per the actuator design within the specified safety time.

Application Restrictions:

The unit must be properly designed into a Safety Instrumented Function per the Safety Manual requirements.



Evaluating Assessor

Certifying Assessor

AEA 1902082 C005

Systematic Capability: SC 3 (SIL 3 Capable)

Random Capability: Type A, Route 2_H Device

**PFH/PFD_{AVG} and Architecture Constraints
must be verified for each application**

Systematic Capability :

The product has met manufacturer design process requirements of Safety Integrity Level (SIL) 3. These are intended to achieve sufficient integrity against systematic errors of design by the manufacturer.

A Safety Instrumented Function (SIF) designed with this product must not be used at a SIL level higher than stated.

Random Capability:

The SIL limit imposed by the Architectural Constraints must be met for each element. This device meets *exida* criteria for Route 2_H.

IEC 61508 Failure Rates in FIT*

Static Application – Clean Service	λ_{SD}	λ_{SU}	λ_{DD}	λ_{DU}
Full Stroke	0	0	0	492
Tight Shut-Off	0	0	0	1038
Open on Trip	0	109	0	383

* FIT = 1 failure / 10⁹ hours

SIL Verification:

The Safety Integrity Level (SIL) of an entire Safety Instrumented Function (SIF) must be verified via a calculation of PFH/PFD_{avg} considering redundant architectures, proof test interval, proof test effectiveness, any automatic diagnostics, average repair time and the specific failure rates of all products included in the SIF. Each element must be checked to assure compliance with minimum hardware fault tolerance (HFT) requirements.

The following documents are a mandatory part of certification:

Assessment Report: AEA 19-02-082 R010 V1R1 (or later)

Safety Manual: R-P-15-11 Rev0 (or later)

**Triple Eccentric
Butterfly Valve (size
1½” to 48” Class
#150 & #300)**

